

Drawn:

DMH

Checked:

T&S BRASS AND BRONZE WORKS, INC.

2 Saddleback Cove / P.O. Box 1088 Travelers Rest, SC 29690 Model No.

EC-3142-8DP

Item No.

Travelers Rest, SC: 800-476-4103 • Simi Valley, CA: 800-423-0150 • Fax: 864-834-3518 • www.tsbrass.com

ChekPoin	t"		This Spa	ace for Architect/E	Engineer Approval
	•		Job Name		Date
ADA Compliant			Model Specifi	ed	Quantity
	Cold		Customer/Wh	olesaler	
			Contractor		
)		Architect/Eng	ineer	
2 5/8" [67mm]	Hot				
Internal Above Deck Electronics w/ Flow Control Setting Switches.		Cast Spout w/ 2.2 GPM [8.3 L/min] Vandal Resistant Aerator		_ - [127	mm]
Powered w/ 6 VDC Lithium Battery.		 Temperature Mixing Ha w/ Color Coded Index 	indle		
		(Optional Plug Included	to 5/8"		
Polished Chrome Plated Deck Plate		Replace Handle When Temperature is Preset)	_	T	6 3/4" [171mm]
w/ Deck Gasket	1		-	-	
	3	Mounting S	urface		
10" [254mm]		8" [203mm]			
		—19" [483mm] Flexible Stainless Steel Supp Hoses		P V	hown w/ Optional lug Installed When /ater Temperature Preset (Included)
		,		1 1/2"	
Optional 100-240 VAC Adapter w/ 71" [1800mm] Power Cord		—1/2" NPSM Swivel Er w/ Filter Washers	nds	[38mm] Maximum	
W -		Check Valve Adapte w/ 3/8" Compression (9/16-24 UN) Inlets		Thickness	
Rough-In Requirement: \emptyset 1 1/4" [32mm] Center Mounting (2) \emptyset 1 1/8" [29mm] Side Mounting	Hole Holes	, - , , , , , ,			
Product Specifications:				Product Complia	ince:
Chrome Plated Brass Above Deck Electronics Faucet, Deck Mount, 8" c/c Deck Plate, Integral Cast Spout w/ 2.2 GPM VR Aerator, Point-of-Use Temperature Control, Battery or AC Adapter Powered, 19" Stainless				ASME A112.18. NSF 61 - Section NSF 372 (Low L	n 9
Steel Flexible Supply Lines & 3/8" Compression Inlets				ANSI A117.1 (AI	

Approved:

JHB

Date:

JRM

UL 1951

Scale:

1:6

Sheet: 1 of 2

11/22/16



T&S BRASS AND BRONZE WORKS, INC.


2 Saddleback Cove / P.O. Box 1088 Travelers Rest, SC 29690

Model No.

EC-3142-8DP

Item No.

Travelers Rest, SC: 800-476-4103 • Simi Valley, CA: 800-423-0150 • Fax: 864-834-3518 • www.tsbrass.com



ITEM NO.	SALES NO.	DESCRIPTION	
1	B-0199-08	VR 2.2 GPM Aerator, 13/16-27 UN Male w/ Key	
2	019087-45	6VDC Lithium Battery, CR-P2	
3	019088-45	Auxiliary Power Connector Cable	
4	019082-45	Lever Asm & Body Screw Kit w/ L-Key	
5	013434-40	8" Universal Deck Plate, Gasket & Mounting Hardware	
6	018544-45	Flexible stainless Steel Hose w/ Check Valve Adapter	
7	5EF-0002	A/C Transformer	
8	019086-45	Body Plug, Pre-Set Temperature	



A maximum of (8) ChekPoint faucets can be powered by EC-HARDWIRE ChekPoint Hardwire AC Transformer when connected using EC-ADEWIRE cables. (Both sold separately)



Optional Plug Replaces Lever Handle When Pre-setting Temperature (Installs from Inside of Body)



015425-45 VR Aerator Key



018543-45 Torx T-20 VR L-Key

Flow Control Switches are Located Behind the Sensor. Remove Battery to Access Switches.

- Switches are set to DEFAULT position:
 - Auto Time Out = 15 seconds
 - Shut Off Delay = 1 second
 - Auto Flush = OFF
- * Available Water Flow Control Selections:
- Auto Time Out: 15 sec, 30 sec, 45 sec, 60 sec, 3 min, 20 min
- Shut Off Delay: 1 sec, 10 sec, 15 sec, 30 sec Auto Flush (30 Seconds After Every 12 Inactive Hours): ON or OFF

Product Specifications:

Chrome Plated Brass Above Deck Electronics Faucet, Deck Mount, 8" c/c Deck Plate, Integral Cast Spout w/ 2.2 GPM VR Aerator, Point-of-Use Temperature Control, Battery or AC Adapter Powered, 19" Stainless Steel Flexible Supply Lines & 3/8" Compression Inlets

Product Compliance:

ASME A112.18.1 / CSA B125.1 NSF 61 - Section 9 NSF 372 (Low Lead Content) ANSI A117.1 (ADA) UL 1951

Drawn: DMH Checked: JRM Approved: JHB Date: 11/22/16 Scale: NTS Sheet: 2 of 2