## T&S BRASS AND BRONZE WORKS, INC.

2 Saddleback Cove / P.O. Box 1088 Travelers Rest, SC 29690

Model No.

EC-3105-VF12

Item No.

Travelers Rest, SC: 800-476-4103 • Simi Valley, CA: 800-423-0150 • Fax: 864-834-3518 • www.tsbrass.com

Short Elbow For [155mm]	This Space for Architect/Engineer Approval  Job NameDate
Restricted Space Installations ChekPoint	Model SpecifiedQuantity
	Customer/Wholesaler
1 15/16"	Contractor
[49mm] ADA Compliar	Architect/Engineer
	4 1/8"
Rigid Gooseneck	[104mm]
w/ B-0199-06-F12 1.2 GPM Vandal	1
Resistant Aerator	1 1/16"
(m)	11" [27mm]
П	[280mm] 15/16"
1/2" NPSM x 3/8" NPSM  30" [762mm] Long Flovible  —Solid Cast Brass Boo	y w/
30" [762mm] Long Flexible Stainless Steel Hose	finish 5 15/16"               Maximum                   Thickness
	<b>↓</b>
24" [610mm]	
24" [610mm] Sensor Cable	Mounting 2 1/4"
	Surface [58mm]
3 5/8" x 4 3	/16" x 2" Deep 06mm x 51mm]
Nater Resi	stant Control Module Box (Blue)
Ctrainer W/ Internal	Flow Control Setting Switches,   Operated w/ (4) AA Batteries.
	apable Using Terminals on Back
100 240 V	AC Adapter w/
71" [1800m	m] Long Power Cable.
(Remove R	ubber Plugs on d Cable to Connect)
ousing since	a dable to dominosty
(2) 3/8" Co	mpression x 1/2" NPSM n] Flexible Stainless Steel
Supply Hos	
Temperature Mixing — Ro	ugh-In Requirement:
Valve w/ Integral Check Valves (2)	1" [25mm] Mounting Holes on 4" [102mm] Centers
Product Specifications:	Product Compliance:

Chrome Plated Brass Electronic Faucet: 4" c/c Wall Mount Rigid Gooseneck w/ 1.2 GPM Vandal Resistant Aerator, AC/DC Control Module w/ Internal Flow Control Setting Switches, Temperature Control Mixing Valve w/ Integral Check Valves & 18" Long Hot & Cold Supply Stop Flexible Connector Hoses

ASME A112.18.1 / CSA B125.1 NSF 61 - Section 9 NSF 372 (Low Lead Content) ANSI A117.1 (ADA) UL 1951

Drawn: GEF Checked: DMH Approved: JHB Date: 10/13/17 Scale: 1:6 Sheet: 1 of




## T&S BRASS AND BRONZE WORKS, INC.

2 Saddleback Cove / P.O. Box 1088 Travelers Rest, SC 29690 Model No.

EC-3105-VF12


Item No.

Travelers Rest, SC: 800-476-4103 • Simi Valley, CA: 800-423-0150 • Fax: 864-834-3518 • www.tsbrass.com



ITEM NO.	SALES NO.	DESCRIPTION
1	015425-45	Vandal Resistant Key
2	B-0199-06-F12	VR Aerator, 1.2 GPM, 55/64-27 Female
3	044A	3/8" to Aerator Adapter
4	006575-45	-015 O-Ring
5	015345-45	Low Profile Elbow, 3/8 NPSM
6	017195-45	Angled Sensor with Cable
7	016325-45	Inlet Hose, Faucet, 1/2" NPSM-F x 3/8" NPSM-F
8	016647-45	ChekPoint Control Module
9	5EF-0002	A/C Transformer
10	5EF-0005	Supply Hose, 9/16-24 Female x 1/2" NPSM
11	5EF-0006	Mechanical Mixing Valve
12	EC-FILTER	Replacement Filter

A Maximum of (8) ChekPoint Faucets can be Hardwire Connected and Powered by EC-HARDWIRE ChekPoint Hardwire AC Transformer. (Sold Separately)



-Label for Flow Control Switch Settings is Located on Inside of Back Cover.

Flow Control Switches are Located Inside Module Housing in Black Box Next to Battery Compartment.

- \*Switches are Set to DEFAULT Position:
- Auto Time Out = 15 Seconds
- Shut Off Delay = 1 Second
- Auto Flush = ÓFF

Remove (4) Screws and Back Cover to Access Switches.

\*Available Water Flow Control Selections:

- Auto Time Out: 15 sec, 30 sec, 45 sec, 60 sec, 3 min, 20 min
- Shut Off Delay: 1 sec, 10 sec, 15 sec, 30 sec
- Auto Flush (30 Seconds After Every 12 Inactive Hours): ON or OFF

**Product Specifications:** 

Chrome Plated Brass Electronic Faucet: 4" c/c Wall Mount Rigid Gooseneck w/ 1.2 GPM Vandal Resistant Aerator, AC/DC Control Module w/ Internal Flow Control Setting Switches, Temperature Control Mixing Valve w/ Integral Check Valves & 18" Long Hot & Cold Supply Stop Flexible Connector Hoses

Product Compliance:

ASME A112.18.1 / CSA B125.1 NSF 61 - Section 9 NSF 372 (Low Lead Content) ANSI A117.1 (ADA) UL 1951

Drawn: GEF Checked: DMH Approved: JHB Date: 10/13/17 Scale: NTS Sheet: 2 of 2

9

10)